

QUALITY TEST REPORT

HOSE : COLDFLEX REFRIGERATION HOSE	SIZE : 3/16"	REPORT NO : 258
CODE : S140005005		ORDER NO : 58166 - 1
LOT : 046		DATE OF TEST : 04.06.2010
FIRM : YUKSEL TEKNİK SOĞUTMA SAN.TİC.LTD.STİ.		DATE OF REPORT : 04.06.2010

TEST NO	TEST NAME	UNIT	SPEC.	RESULTS	TEST METHOD
1.0	<u>DIMENSION CONTROL 23 ±2 ° C</u>				TS EN ISO 4671
1.1	INSIDE DIAMETER	mm	4,80 - 5,00	4,9	
1.2	OUTSIDE DIAMETER	mm	8,00 - 8,20	8,1	
1.3	WALL THICKNESS	mm	1,6 - 1,8	1,6	
1.4	WEIGHT	g/m	35 - 45	35	
1.5	MIN. BENDING RADIUS	mm	25	OK	
2.0	<u>HYDROSTATIC TEST 23 ±2 ° C</u>				EN ISO 1402
2.1	WORKING PRESSURE	bar	112	OK	
2.2	CHANGE IN LENGTH (W.P.)	%	(-) 3 / (+) 3	0,8	
2.3	CHANGE IN DIAMETER (W.P.)	%	(-) 3 / (+) 3	2,46	
2.4	PROOF PRESSURE	bar	224	OK	
2.5	BURST PRESSURE	bar	Min. 450	566	

APPROVE
Muhammet ÇETİN