

QUALITY TEST REPORT

HOSE : COLDFLEX REFRIGERATION HOSE 1/12" CODE : S140002002 (KIRMIZI) LOT : 076 FIRM : YUKSEL TEKNİK SOGUTMA SAN.TIC.LTD.STI.	REPORT NO : 888 ORDER NO : 86862/03 DATE OF TEST : 13.10.2011 DATE OF REPORT : 13.10.2011
---	--

TEST NO	TEST NAME	UNIT	SPEC.	RESULTS	TEST METHOD
1.0	DIMENSION CONTROL				ISO 4671
1.1	INSIDE DIAMETER	mm	2,10 - 2,30	2,15	
1.2	OUTSIDE DIAMETER	mm	5,55 - 5,65	5,64	
1.3	WALL THICKNESS	mm	1,62 - 1,82	1,74	
2.0	HYDROSTATIC TEST				EN ISO 1402
2.1	MAX. WORKING PRESSURE	bar	50	50	
2.2	CHANGE IN LENGTH (W.P.)	%	(-) 3 / (+) 3	-1,2	
2.3	PROOF TEST	bar	100	OK	
2.4	BURST PRESSRE	bar	700	1013	
2.5	WEIGHT	g/m	20-30	25	
3.0	<u>YAPIŞMA KUVVETİ 23 ±2 ° C</u>				ISO 8033
3.1	ALT KAT	kgf/cm	Min. 1,5	OK	
4.0	NITROJEN TEST FOR ALL COILS (70-100 bar, 3 min.)		NO LEAK	OK	METHOD:987